

PROFORMA REGARDING HEALTH AND SANITARY CONDITION CERTIFICATE

No. Memo/2023-24

Dated: 13.11.2023

It is certified that an inspection team headed by Abhishek Kumar Chaubey (Name of Officers with designation) from Food Sanitary Inspector, Nagar Palika Parishad Lalitpur (Name of Department/Office) inspected the WISTERIA ACADEMY at Rawatyana, Old Jhansi Road, Lalitpur, UP 284403 (Name & Address of the school) on 13.11.2023 and found that the WISTERIA ACADEMY (Name of school) has clean and pollution free surrounding facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per the norms prescribed by the Central/State/U.T Govt.

Signature with Seal

: Abhishek

Name

: Abhishek Kumar Chaubey

Designation

: Food Sanitary Inspector

Nagar Palika Parishad  
Lalitpur (U.P.)

To,

Wisteria Academy

Old Jhansi Road,

Lalitpur, UP - 284403

(Name & Address of the Institution)



**PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE**No. Memo/2023-24Dated: 13.11.2023

It is certified that an inspection team headed by Abhishek Kumar Chaubey (Name of Officers with Designation from For Sanitary Inspector Nagar Palika Parishad Lalitpur (Name of Department/Office) inspected the WISTERIA ACADEMY at Rawatyana, Old Jhansi Road, Lalitpur, UP 284403 (Name & Address of the school) on 13.11.2023 and found that the WISTERIA ACADEMY (Name of school) as safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per the norms prescribed by the Central/State/U.T Govt.

The above valid for a period of 13.11.2023 to 12.11.2024

Signature with Seal

: @chaubey

Name

: Abhishek Kumar Chaubey

Designation

: For Sanitary Inspector  
Nagar Palika Parishad  
Lalitpur (U.P.)

To,

Wisteria AcademyOld Jhansi Road,Lalitpur, UP - 284403

(Name &amp; Address of the Institution)





CIN: U73100MP2002PTC015352

GSTIN: 23AAECA9188L1Z8

Approved: by Occupational Health & Safety Management (ISO45001:2018)

Approved: by National Accreditation Board for Testing and Calibration Laboratories



Registered Office: 63/1, Kailash Vihar, Near Income Tax Office, City Center-II

Gwalior-474 011, M.P., India

☎ 0751-3566867, 2232177

Email: aelgwalior@gmail.com, aetri2016@gmail.com, aetrlcenter@gmail.com

Web: www.aetrl.com



## TEST REPORT

<b>Company name</b>	: wisteria Academy	<b>D/o Report Issue</b>	: 04/03/2024
<b>Address</b>	: Near parinay banquet hall ,Sagar road, chowkabaag lalitpur (U.P.)	<b>D/o Sample Received</b>	: 26/02/2024
<b>Nature of Sample</b>	: Water sample-1	<b>Qty of Sample</b>	: 1000ml Each
<b>Lab.Ref.No.</b>	: AETRL/260224W0001	<b>Sample Bottle</b>	: Plastic Bottle
<b>Sample Collected by</b>	: Customer	<b>Sample Description</b>	: Dialysis Water
<b>Dispatch No.</b>	: 0010	<b>Date of Sample collection</b>	: 25/02/2024
<b>URL No</b>	: TC1278024000000137F		

## TEST RESULT

Sr.No.	PARAMETERS	UNIT	TEST RESULTS	Specification IS:10500		Method IS:3025
				(Acceptable Limit)	(Permissible Limit)	
1.	pH	-	7.05	6.5-8.5	No relaxation	PART-11
2.	Colour	Hazan	<1.0	5	15	PART-4
3.	Turbidity, NTU	NTU	<1.0	1	5	PART-10
4.	Dissolved solids	mg/L	10	500	2000	PART-16
5.	Total Hardness	mg/L	8	200	600	PART-21
6.	Total alkalinity	mg/L	6	200	600	PART-23
7.	Chlorides	mg/L	2.60	250	1000	PART-32
8.	Residual chlorine*	mg/L	BDL	0.2	1.0	PART-26
9.	Calcium as Ca <sup>2+</sup>	mg/L	2.24	75	200	PART-40
10.	Magnesium as Mg <sup>2+</sup>	mg/L	0.58	30	100	PART-46
11.	Sulphate	mg/L	BDL	200	400	PART-24
12.	Nitrate	mg/L	BDL	45	No relaxation	PART-34
13.	Fluoride	mg/L	BDL	1.0	1.5	PART-60
14.	Iron as Fe	mg/L	BDL	0.3	No relaxation	PART-53
15.	Total Coliform	Per100MI	Absent	Absent	No relaxation	IS:15185:2016 (R-2021)
16.	E. coli	Per100MI	Absent	Absent	No relaxation	IS:15185:2016 (R-2021)

(Authorized signature)



Registered Office: 63/1, Kailash Vihar, Near Income Tax Office, City Center-II

Gwalior-474 011, M.P., India

☎0751-3566867, 2232177

Email: aetlgwalior@gmail.com aetrl2016@gmail.com, aetrlcenter@gmail.com

Web: www.aetrl.com



TC-12780

## TEST REPORT

<b>Company name</b>	: wisteria Academy	<b>D/o Report Issue</b>	: 04/03/2024
<b>Address</b>	: Near parinay banquet hall ,Sagar road, chowkabaag lalitpur (U.P.)	<b>D/o Sample Received</b>	: 26/02/2024
<b>Nature of Sample</b>	: Water sample -2	<b>Qty of Sample</b>	: 1000ml Each
<b>Lab.Ref.No.</b>	: AETRL/260224W0002	<b>Sample Bottle</b>	: Plastic Bottle
<b>Sample Collected by</b>	: Customer	<b>Sample Description</b>	: Raw Water
<b>Dispatch No.</b>	: 0010	<b>Date of Sample collection</b>	: 25/02/2024
<b>URL No</b>	: TC1278024000000138F		

## TEST RESULT

Sr.No.	PARAMETERS	UNIT	TEST RESULTS	Specification IS:10500		Method IS:3025
				(Acceptable Limit)	(Permissible Limit)	
1.	pH	-	7.18	6.5-8.5	No relaxation	PART-11
2.	Colour	Hazan	<1.0	5	15	PART-4
3.	Turbidity, NTU	NTU	<1.0	1	5	PART-10
4.	Dissolved solids	mg/L	628	500	2000	PART-16
5.	Total Hardness	mg/L	296	200	600	PART-21
6.	Total alkalinity	mg/L	280	200	600	PART-23
7.	Chlorides	mg/L	30.40	250	1000	PART-32
8.	Residual chlorine*	mg/L	BDL	0.2	1.0	PART-26
9.	Calcium as Ca <sup>2+</sup>	mg/L	82.40	75	200	PART-40
10.	Magnesium as Mg <sup>2+</sup>	mg/L	21.87	30	100	PART-46
11.	Sulphate	mg/L	27.39	200	400	PART-24
12.	Nitrate	mg/L	2.16	45	No relaxation	PART-34
13.	Fluoride	mg/L	BDL	1.0	1.5	PART-60
14.	Iron as Fe	mg/L	0.157	0.3	No relaxation	PART-53
15.	Total Coliform	Per100MI	Absent	Absent	No relaxation	IS:15185:2016 (R-2021)
16.	E. coli	Per100MI	Absent	Absent	No relaxation	IS:15185:2016 (R-2021)

(Authorized signature)



Registered Office: 63/1, Kailash Vihar, Near Income Tax Office, City Center-II

Gwalior-474 011, M.P., India

☎0751-3566867, 2232177

Email: aetlgwalior@gmail.com aetrl2016@gmail.com, aetrlcenter@gmail.com

Web: www.aetrl.com



TC-12780

## TEST REPORT

<b>Company name</b>	: wisteria Academy	<b>D/o Report Issue</b>	: 04/03/2024
<b>Address</b>	: Near parinay banquet hall ,Sagar road, chowkabaag lalitpur (U.P.)	<b>D/o Sample Received</b>	: 26/02/2024
<b>Nature of Sample</b>	: Water sample -3	<b>Qty of Sample</b>	: 1000ml Each
<b>Lab.Ref.No.</b>	: AETRL/260224W0003	<b>Sample Bottle</b>	: Plastic Bottle
<b>Sample Collected by</b>	: Customer	<b>Sample Description</b>	: Ro Water
<b>Dispatch No.</b>	: 0010	<b>Date of Sample collection</b>	: 25/02/2024
<b>URL No</b>	: TC1278024000000139F		

## TEST RESULT

Sr.No.	PARAMETERS	UNIT	TEST RESULTS	Specification IS:10500		Method IS:3025
				(Acceptable Limit)	(Permissible Limit)	
1.	pH	-	7.01	6.5-8.5	No relaxation	PART-11
2.	Odor	-	Agreeable	Agreeable	Agreeable	PART-5
3.	Turbidity, NTU	NTU	<1.0	1	5	PART-10
4.	Dissolved solids	mg/L	24	500	2000	PART-16
5.	Total Hardness	mg/L	10	200	600	PART-21
6.	Total alkalinity	mg/L	5	200	600	PART-23
7.	Chlorides	mg/L	2.60	250	1000	PART-32
8.	Residual chlorine*	mg/L	BDL	0.2	1.0	PART-26
9.	Calcium as Ca <sup>2+</sup>	mg/L	2.8	75	200	PART-40
10.	Magnesium as Mg <sup>2+</sup>	mg/L	0.72	30	100	PART-46
11.	Sulphate	mg/L	BDL	200	400	PART-24
12.	Nitrate	mg/L	BDL	45	No relaxation	PART-34
13.	Fluoride	mg/L	BDL	1.0	1.5	PART-60
14.	Iron as Fe	mg/L	BDL	0.3	No relaxation	PART-53
15.	Total Coliform	Per100MI	Absent	Absent	No relaxation	IS:15185:2016 (R-2021)
16.	E. coli	Per100MI	Absent	Absent	No relaxation	IS:15185:2016 (R-2021)

(Authorized signature)